

# THE TINTON FALLS SCHOOL DISTRICT



**ADMINISTRATIVE OFFICES**  
**658 TINTON AVENUE**  
**TINTON FALLS, NJ 07724**  
**(732) 460-2400**  
**FAX (732) 542-1158**  
<http://tfschools.org>

Lisa Goldey, Ed.D  
Superintendent of Schools

Kerri Lee Walsifer  
Director of Special Services

Vincent Daniels  
Business Administrator/Board Secretary

December 2, 2021

Dear Parents/Guardians:

The Tinton Falls School District continues to be committed to providing a safe environment for all staff and students. As required by the Department of Education and N.J.A.C. 6A:26-12.4, all public schools are required to test for lead in drinking water every three years.

Samples were collected from all drinking fountains and outlets from where water may be consumed. These samples were sent to a certified laboratory for analysis. This process was facilitated by Ramm Environmental Services, Inc., an environmental consulting and training firm located in Bergen County, Fair Lawn, New Jersey.

From all the samples collected the following was noted:

School	Results ug/l (ppb)	Action Plan if needed
MFA - Room 103 (sink)	17.4 ppb	"Handwashing only" sign was hung by sink
MFA - Room 108 (sink)	15.4 ppb	"Handwashing only" sign was hung by sink
MFA - Faculty Room 171A (sink)	18.6 ppb	"Handwashing only" sign was hung by sink
TFMS - Room 550-A (sink)	35.4 ppb	"Handwashing only" sign was hung by sink

You can find the full reports regarding water testing on our website at [www.tfschools.org](http://www.tfschools.org), under the parent tab.

For more information, about the water quality in our schools, please contact Mr. Vincent Daniels, Business Administrator at 732-460-2406. For information about water quality, sampling, and FAQs, please visit the Department of Environmental Protection: Division of Water Supply and Geoscience website, [linked here](#).

Sincerely,

Lisa Goldey, Ed.D.  
Superintendent of Schools